


Appendix D: ADA Self- Assessment



Charles T. Blanchard
Town Manager

Town of Palmer

“Bondsville, Depot Village, Thorndike & Three Rivers”

Palmer Town Building
4417 Main Street
Palmer, MA 01069
Town: (413) 283-2603
Cell: (317) 667-4672
cblanchard@townofpalmer.com

August 28, 2014

Executive Office of Environmental Affairs
100 Cambridge Street, Suite 900
Boston, MA 02114-2524

Re: Town of Palmer – Open Space and Recreation Plan – ADA Compliance Testament


To Whom It May Concern:

This letter is to confirm that the Town of Palmer’s hiring and employment practices are consistent with standards and requirements of the Americans with Disabilities Act. These include recruitment, personnel actions, leave administration, training, tests, medical exam/questionnaires, social and recreational programs, collective bargaining agreements and wage and salary administration.

If I can provide any additional information, please contact me.

Sincerely,

Charles T. Blanchard,
Town Manager



Charles T. Blanchard
Town Manager

Town of Palmer

“Bondsville, Depot Village, Thorndike & Three Rivers”

Palmer Town Building
4417 Main Street
Palmer, MA 01069
Town: (413) 283-2603
Cell: (317) 667-4672
cblanchard@townofpalmer.com

Grievance Policy

Equal Access to Facilities and Activities

Maximum opportunity will be made available to receive citizen comments, complaints, and/or resolve grievances or inquiries.

STEP 1:

The Town Manager will be available to meet with citizens and employees during business hours.

When a complaint, grievance, request for program policy interpretation or clarification is received either in writing or through a meeting or telephone call, every effort will be made to create a record regarding the name, address and telephone number of the person making the complaint, grievance, program policy interpretation or clarification. If the person desires to remain anonymous they may.

A complaint, grievance, request for program policy interpretation or clarification will be responded to within ten working days (if the person making the complaint is identified) in a format that is sensitive to the needs of the recipient, (i.e. verbally, enlarged type face, etc.).

STEP 2:

A written grievance will be submitted to the Town Manager. Assistance in writing the grievance will be available to all individuals. All written grievances will be responded to within ten working days by the Town Manager in a format that is sensitive to the needs of the recipient, (i.e. verbally, enlarged type face, etc.). If the grievance is not resolved at this level it will be progressed to the next level.


STEP 3:

If the grievance is not satisfactorily resolved, citizens will be informed of the opportunity to meet and speak with the Architectural Access Board, with whom authority for final grievance resolution lies.

**TOWN OF PALMER
DEPARTMENT OF PUBLIC WORKS
CEMETERY DIVISION**

The Town of Palmer is accepting applications for the non-benefit position of on-call seasonal laborer in the Public Works Cemetery Division. Duties to include mowing and trimming of town cemeteries and any other duties as directed by the Cemetery Division foreman. Hours depend on weather conditions; rate of pay is \$ per hour. Mass. Driver's license required. For info call 283-2664. Applications can be obtained and submitted to the Town Manager's Office, 4417 Main St., Palmer, Monday through Friday 9AM to 4 PM and will be accepted until the position is filled.

Palmer is an EOE/AA employer.



Charles T. Blanchard
Town Manager

Town of Palmer

“Bondsville, Depot Village, Thorndike & Three Rivers”

Palmer Town Building
4417 Main Street
Palmer, MA 01069
Town: (413) 283-2603
cblanchard@townofpalmer.com

August 14, 2014

Executive Office of Environmental Affairs
100 Cambridge Street, Suite 900
Boston, MA 02114-2524

Re: Town of Palmer – Americans with Disabilities Act Coordinator

To Whom It May Concern:

Please be advised that Zoning Enforcement Officer Bonita Weeks has been appointed as the Town’s ADA Coordinator. She has served in this capacity with the Town of Palmer since July 1, 2013.

Sincerely,

Charles T. Blanchard

Charles T. Blanchard,
Town Manager

ADA Transition Plan

Facility Name	Endelson Playground		
Jurisdiction	Recreation Department & Parks Department		
Location	Main Street		
Total Acreage	1.60		
Activity	Basketball, Playground		
Site Amenities (equipment)	Swings, Slide, Basketball Hoop		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking	Locate and Install ADA accessible parking spaces	2015	Recreation Department & Parks Department
Could be River access, area needs to be cleared	Design and construct accessible path to River	2015	Recreation Department & Parks Department
Playground old and in disrepair	Replace with ADA accessible play equipment	2015	Recreation Department & Parks Department

Facility Name	Bondsville Grammar Park		
Jurisdiction	Recreation Department & Parks Department		
Location	Main Street		
Total Acreage	1.07		
Activity	Play Area, Green, Monument, Path of Travel		
Site Amenities (equipment)	Benches, small path, small open grassy area, passive park		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces	2019	Recreation Department & Parks Department
Path of Travel not wheel chair accessible	Widen current path to meet ADA requirements	2019	Recreation Department & Parks Department

ADA Transition Plan

Facility Name	Burleigh Park/Burleigh Brook Recreation Area		
Jurisdiction	Recreation Department & Parks Department		
Location	Old Warren Road		
Total Acreage	156.81		
Activity	Sports, Hiking, Picnicking		
Site Amenities (equipment)	Soccer, Baseball, Basketball, Horseshoes, Trail Network		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces	2015	Recreation Department & Parks Department
No accessible path of travel.	Design and construct accessible path	2015	Recreation Department & Parks Department
Trails are inaccessible due to slope, grade, materials	Design and construct accessible trail system	2018	Recreation Department & Conservation Commission
No accessible restrooms	Add ADA accessible facilities	2017	Recreation Department & Parks Department
Trash cans not on path	Relocate trash can to accessible location	2015	Recreation Department & Parks Department
No accessible seating/benches/Picnic area	Add ADA accessible seating & Picnic shelters	2015	Recreation Department & Parks Department

Facility Name	Water Street Field		
Jurisdiction	Recreation Department & Parks Department		
Location	Water Street		
Total Acreage	7.23		
Activity	Soccer		
Site Amenities (equipment)	Open Field		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces	2019	Recreation Department & Parks Department

ADA Transition Plan

Facility Name	Eager Playground/Legion Field		
Jurisdiction	Recreation Department & Parks Department		
Location	Rathbone Street		
Total Acreage	23.00		
Activity	Sports, Picnic, Wadding Pool		
Site Amenities (equipment)	Playground for K-3, Playground for 5-12, Tennis Courts, Wading Pool		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces	2014	Recreation Department & Parks Department
No accessible path of travel.	Design and construct accessible path	2015	Recreation Department & Parks Department
Out of date playground equipment	Upgrade playground equipment, add padding under equipment	2014	Recreation Department & Parks Department
Trash cans not accessible	Relocate trash can to accessible location	2018	Recreation Department & Parks Department
No accessible seating/benches/Picnic area	Add ADA accessible seating & Picnic shelters	2019	Recreation Department & Parks Department

Facility Name	Hryniewicz Park		
Jurisdiction	Recreation Department & Parks Department		
Location	Main Street, Three Rivers		
Total Acreage	1.02		
Activity	Picnicking, playgrounds, concerts, events		
Site Amenities (equipment)	Benches, playground, gazebo, ADA Parking		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
None	Site is very ADA accessible		

ADA Transition Plan

Facility Name	Walter "Bebe" Chase Memorial Field		
Jurisdiction	Recreation Department & Parks Department		
Location	Shaw Street		
Total Acreage	24.02		
Activity	Sports		
Site Amenities (equipment)	Soccer Field, Open Space		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking	Locate and Install ADA two accessible parking spaces & signage	2019	Recreation Department & Parks Department
No path of travel, site has 1%-2% slopes	Add ADA accessible path of travel	2018	Recreation Department & Parks Department
Trash cans not on path	Relocate trash can to accessible location	2018	Recreation Department & Parks Department
No accessible seating/benches/Picnic area	Add ADA accessible seating & Picnic shelters	2019	Recreation Department & Parks Department

Facility Name	Veterans Monument		
Jurisdiction	Parks Department , Town of Palmer		
Location	Church Street/River Road		
Total Acreage	0.19		
Activity	Site Seeing, Passive		
Site Amenities (equipment)	Monument, Memorials		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces	2020	DPW

ADA Transition Plan

Facility Name	Memorial Park (WWI Monument)		
Jurisdiction	Parks Department , Town of Palmer		
Location	Park Street & Converse Street		
Total Acreage	0.28		
Activity	Monument, Memorial		
Site Amenities (equipment)	Benches, Sidewalk		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No designated ADA parking	Locate and Install ADA accessible parking spaces	2020	Parks Department & DPW

Facility Name	Three Rivers Well Field		
Jurisdiction	Parks Department, Town of Palmer		
Location	Oak Street		
Total Acreage	44.42		
Activity	None		
Site Amenities (equipment)	Open field/Open Space		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Not Applicable Not Accessible to Public			

ADA Transition Plan

Facility Name	Lavoliette Field		
Jurisdiction	Recreation Department & Parks Department		
Location	2015 Main Street		
Total Acreage	15.81		
Activity	Sports		
Site Amenities (equipment)	Baseball Fields, Soccer Fields, Restrooms		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No ADA accessible or Public Parking - On street parking only	Locate and Install ADA accessible parking spaces.	2015	Recreation Department & Parks Department
No accessible path of travel.	Design and construct accessible path	2015	Recreation Department & Parks Department
Trails are inaccessible due to slope, grade, materials	Design and construct accessible trail system	2018	Recreation Department & Conservation Commission
No accessible restrooms	Add ADA accessible facilities	2017	Recreation Department & Parks Department
No accessible seating/benches/Picnic area	Add ADA accessible seating & Picnic shelters	2015	Recreation Department & Parks Department

Facility Name	Midura Family Conservation Lands		
Jurisdiction	Conservation Commission		
Location	Old Warren Road		
Total Acreage	219.00		
Activity	Hiking, Biking, Nature Study/Observation, Wildlife Management		
Site Amenities (equipment)	Trail Network		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No Designated Handicapped Parking			Conservation Commission
Trails are inaccessible due to slope, grade and surfacing	Accessible Trail to be provided at another location		Conservation Commission

ADA Transition Plan

Facility Name	Mountain Roads Trail System		
Jurisdiction	Conservation Commission		
Location	Onley Rd, Mountain Rd, St Johns Rd, McMasters Rd, Bacon Rd, Rondeau Rd, Browns Rd, Tavern Rd		
Total Acreage	128.65 (8 miles of old roads)		
Activity	Hiking, Biking, Nature Study/Observation, Wildlife Management		
Site Amenities (equipment)	Trail Network		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No Parking for Anyone Trails are inaccessible due to slope, grade and surfacing	Allow authorized ATV/ORV access to Mountain Road System to people with disabilities		Conservation Commission

Facility Name	Ware River Waterfront		
Jurisdiction	Town of Palmer		
Location	Main Street		
Total Acreage	13.01		
Activity	Fishing, Boating, Swimming		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Land Locked/No Access Public Use not Applicable			

ADA Transition Plan

Facility Name	Red Bridge Connection		
Jurisdiction	Town of Palmer		
Location	Springfield Street		
Total Acreage	8.08		
Activity	Fishing, Boating, Swimming		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Land Locked/No Access Public Use not Applicable			

Facility Name	Swift River Greenbelt		
Jurisdiction	Conservation Commission		
Location	River Road		
Total Acreage	15.01		
Activity	Fishing, Boating, Swimming		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No Accessible Path of Travel No Designated Parking			

ADA Transition Plan

Facility Name	Industrial Park Green Belt		
Jurisdiction	Conservation Commission		
Location	Second Street		
Total Acreage	24.8		
Activity	Fishing, Boating, Swimming		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
No Accessible Path of Travel No Designated Parking			

Facility Name	Shaw District		
Jurisdiction	Conservation Commission		
Location	Tavern Rd, Brown Rd, West Ware Rd, Bacon Rd		
Total Acreage	240.60		
Activity	None, Public Use Not Applicable		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Land Locked/No Access Public Use not Applicable			

ADA Transition Plan

Facility Name	Old B&A Railroad Bed		
Jurisdiction	Conservation Commission		
Location	Barker Street		
Total Acreage	6.50		
Activity	Possible Trail Connectivity, but currently No Public Access		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Land Locked/No Access Public Use not Applicable			

Facility Name	Grand Trunk Railroad Bed		
Jurisdiction	Conservation Commission		
Location	River Road		
Total Acreage	2.40		
Activity	Possible Trail Connectivity, but currently No Public Access		
Site Amenities (equipment)	None		
Transition Plan			
Barriers to Access	Corrective Actions	Scheduled Changes	Authority
Land Locked/No Access Public Use not Applicable			

Facility Inventory

LOCATION: Water Street Field

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface Located adjacent to accessible paths
Trash Cans	Located adjacent to accessible paths	
Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails Location from accessible parking Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Water Street Field

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>		<i>Required Accessible Spaces</i>
Up to 25			1 Space
26-50			2 Spaces
51-75			3 Spaces
76-100			4 Spaces
101-150			5 Spaces
151-200			6 Spaces
201-300			7 Spaces
301-400			8 Spaces
401-500			9 Spaces
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Water Street Field

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Water Street Field

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Water Street Field

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Water Street Field

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Water Street Field

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Water Street Field

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Water Street Field

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Ware River Waterfront

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface Located adjacent to accessible paths
Trash Cans	Located adjacent to accessible paths	
	Located adjacent to accessible paths	
Picnic Shelters	Located adjacent to accessible paths	
	Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Location from accessible parking Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Ware River Waterfront

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Ware River Waterfront

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Ware River Waterfront

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Ware River Waterfront

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Ware River Waterfront

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Ware River Waterfront

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Ware River Waterfront

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Ware River Waterfront

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Veterans Monument

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Location from accessible parking
		Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
Enough space between equipment for wheelchair		
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	

LOCATION: Veterans Monument

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Veterans Monument

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Veterans Monument

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Veterans Monument

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Veterans Monument

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Veterans Monument

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Veterans Monument

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Veterans Monument

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Three Rivers Well Field

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

NOTES: It is an open mown field that you can walk around on.

LOCATION: Three Rivers Well Field

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 Space		
26-50	2 Spaces		
51-75	3 Spaces		
76-100	4 Spaces		
101-150	5 Spaces		
151-200	6 Spaces		
201-300	7 Spaces		
301-400	8 Spaces		
401-500	9 Spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: No parking or Ramps

LOCATION: Three Rivers Well Field

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		x	no paths just open field
Disembarking area at accessible entrance		x	
Surface evenly paved or hard-packed		x	
No ponding water		x	
Path of Travel			
Path does not require the use of stairs		x	
Path is stable, firm, and slip resistant		x	
3 ft wide minimum		x	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		x	
Continuous common surface, no changes in level greater than 1/2 inch		x	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		x	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		x	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		x	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		x	
Level space extending 5 ft from the door, interior and exterior of entrance doors		x	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		x	
At least 18" clear floor area on latch, pull side of door		x	
Door handle no higher than 48" and operable with a closed fist		x	
Vestibule is 4 ft plus the width of the door swinging into the space		x	
Entrance(s) on a level that makes elevators accessible		x	
Door mats less than 1/2" thick are securely fastened		x	
Door mats more than 1/2" thick are recessed		x	
Grates in path of travel have openings of 1/2" maximum		x	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		x	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		x	

NOTES: no grates, signage or usable structures

LOCATION: Three Rivers Well Field

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No stairs, doors, usable structure

LOCATION: Three Rivers Well Field

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: One ADA approved 'Port-o-Potty' with broken door

LOCATION: Three Rivers Well Field

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: Not Applicable, None of the Above

LOCATION: Three Rivers Well Field**SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

LOCATION: Three Rivers Well Field**SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

LOCATION: Three Rivers Well Field**PICNICKING**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTES: Not Applicable, None of the Above

Facility Inventory

LOCATION: Thorndike Playground

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

NOTES: Just a TOT LOT. not ADA Accessable

LOCATION: Thorndike Playground

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 Space		
26-50	2 Spaces		
51-75	3 Spaces		
76-100	4 Spaces		
101-150	5 Spaces		
151-200	6 Spaces		
201-300	7 Spaces		
301-400	8 Spaces		
401-500	9 Spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		X	No Handicap Parking
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		X	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		X	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		X	
Sign with international symbol of accessibility at each space or pair of spaces		X	
Sign minimum 5ft, maximum 8ft to top of sign		X	
Surface evenly paved or hard-packed (no cracks)		X	
Surface slope less than 1:20, 5%		X	
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		X	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		X	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		X	
Minimum width 4 ft between hand rails		X	
Handrails on both sides if ramp is longer than 6 ft		X	
Handrails at 34" and 19" from ramp surface		X	
Handrails extend 12" beyond top and bottom		X	
Handgrip oval or round		X	
Handgrip smooth surface		X	
Handgrip diameter between 1 1/4" and 2"		X	
Clearance of 1 1/2" between wall and wall rail		X	
Non-slip surface		X	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		X	

NOTES: Gravel Parking Lot. No Ramps

LOCATION: Thorndike Playground

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water	X		
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: No real path from parking area, Enter through fence opening from town sidewalk

LOCATION: Thorndike Playground

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No stairs, doors, usable structure

LOCATION: Thorndike Playground

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: NO Restrooms

LOCATION: Thorndike Playground

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: Not Applicable, None of the Above

LOCATION: Thorndike Playground**SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

LOCATION: Thorndike Playground**SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

LOCATION: Thorndike Playground**PICNICKING**

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTES: Not Applicable, None of the Above

Facility Inventory

LOCATION: Swift River Green Belt

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths	
		Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths	
		Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
Boat Docks	Access Routes	Spectator Seating	
		Located adjacent to accessible paths	
Fishing Facilities	Access Routes	Handrails	
		Located adjacent to accessible paths	
	Equipment	Handrails	
		Arm Rests	
		Bait Shelves	
Programming	Are special programs at your facilities accessible?	Handrails	
		Fish Cleaning Tables	
		Learn-to-Swim	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	Guided Hikes	
		Interpretive Programs	
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

LOCATION: Swift River Green Belt

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>		<i>Required Accessible Spaces</i>
Up to 25			1 Space
26-50			2 Spaces
51-75			3 Spaces
76-100			4 Spaces
101-150			5 Spaces
151-200			6 Spaces
201-300			7 Spaces
301-400			8 Spaces
401-500			9 Spaces
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Swift River Green Belt

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Swift River Green Belt

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Swift River Green Belt

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Swift River Green Belt

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Swift River Green Belt

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Swift River Green Belt

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Swift River Green Belt

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Shaw District

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking Shade provided		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
Enough space between equipment for wheelchair		
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
Spectator Seating		
Boat Docks	Access Routes	Located adjacent to accessible paths Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	

LOCATION: Shaw District

PARKING			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	
NOTES: No Parking, no foot access			

LOCATION: Shaw District

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES:

LOCATION: Shaw District

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Shaw District

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Shaw District

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Shaw District

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Shaw District

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Shaw District

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Red Bridge Connection

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
Fishing Facilities	Access Routes	Handrails
		Located adjacent to accessible paths
	Equipment	Arm Rests
		Bait Shelves
		Handrails
Programming	Are special programs at your facilities accessible?	Fish Cleaning Tables
		Learn-to-Swim
		Guided Hikes
Services and Technical Assistance		Interpretive Programs
	Information available in alternative formats i.e. for visually impaired	Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Red Bridge Connection

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Red Bridge Connection

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Red Bridge Connection

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Red Bridge Connection

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Red Bridge Connection

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Red Bridge Connection

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Red Bridge Connection

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Red Bridge Connection

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: PUBLIC ACCESS TO FOREST LAKE

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface Located adjacent to accessible paths
Trash Cans	Located adjacent to accessible paths	
Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water NO
		Handrails NO
Location from accessible parking NO Shade provided NO		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks NO	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities NO	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

NOTES: None of the above. Beach Area adjacent to on street parking. Just sand with curb cut and an unimproved boat launch area.

LOCATION: PUBLIC ACCESS TO FOREST LAKE

PARKING			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25	X	1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		X	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		X	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		X	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		X	
Sign with international symbol of accessibility at each space or pair of spaces		X	
Sign minimum 5ft, maximum 8ft to top of sign		X	
Surface evenly paved or hard-packed (no cracks)	X		
Surface slope less than 1:20, 5%	X		
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present	X		
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	X		
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		X	
Minimum width 4 ft between hand rails		X	
Handrails on both sides if ramp is longer than 6 ft		X	
Handrails at 34" and 19" from ramp surface		X	
Handrails extend 12" beyond top and bottom		X	
Handgrip oval or round		X	
Handgrip smooth surface		X	
Handgrip diameter between 1 1/4" and 2"		X	
Clearance of 1 1/2" between wall and wall rail		X	
Non-slip surface		X	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		X	

NOTES: Not Applicable, No Ramps

LOCATION: PUBLIC ACCESS TO FOREST LAKE

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed	X		
No ponding water	X		
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant	X		
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		X	
Nosings not projecting		X	
Treads no less than 11" wide		X	
Handrails on both sides		X	
Handrails 34"-38" above tread		X	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		X	
Handgrip oval or round		X	
Handgrip has a smooth surface		X	
Handgrip diameter between 1 1/4" and 1 1/2"		X	
1 1/2" clearance between wall and handrail		X	
Doors			
Minimum 32" clear opening		X	
At least 18" clear floor space on pull side of door		X	
Closing speed minimum 3 seconds to within 3" of the latch		X	
Maximum pressure 5 pounds interior doors		X	
Threshold maximum 1/2" high, beveled on both sides		X	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		X	
Hardware minimum 36", maximum 48" above the floor		X	
Clear, level floor space extends out 5 ft from both sides of the door		X	
Door adjacent to revolving door is accessible and unlocked		X	
Doors opening into hazardous area have hardware that is knurled or roughened		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

NOTES: Not Applicable

LOCATION: PUBLIC ACCESS TO FOREST LAKE

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTES: Not Applicable

Facility Inventory

LOCATION: Mountain Roads Trail System

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking Shade provided		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Mountain Roads Trail System

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>		<i>Required Accessible Spaces</i>
Up to 25			1 Space
26-50			2 Spaces
51-75			3 Spaces
76-100			4 Spaces
101-150			5 Spaces
151-200			6 Spaces
201-300			7 Spaces
301-400			8 Spaces
401-500			9 Spaces
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Mountain Roads Trail System

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Mountain Roads Trail System

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Mountain Roads Trail System

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Mountain Roads Trail System

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Mountain Roads Trail System

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Mountain Roads Trail System

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Mountain Roads Trail System

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Midura Family Conservation Land

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	

LOCATION: Midura Family Conservation Land

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Midura Family Conservation Land

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Midura Family Conservation Land

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Midura Family Conservation Land

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Midura Family Conservation Land

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Midura Family Conservation Land

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Midura Family Conservation Land

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Midura Family Conservation Land

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Memorial Field (WW1 Monument)

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance		Information available in alternative formats i.e. for visually impaired
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Memorial Field (WW1 Monument)

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Memorial Field (WW1 Monument)

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Memorial Field (WW1 Monument)

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Memorial Field (WW1 Monument)

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Memorial Field (WW1 Monument)

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Memorial Field (WW1 Monument)

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Memorial Field (WW1 Monument)

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Memorial Field (WW1 Monument)

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: Lavolette Field

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

Notes: Open field with soccer nets. One bench 25' long 18" high. Everything else N/A

LOCATION: Laviolette Field

PARKING			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	no handicapped spots
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	gravel and sod
Surface slope less than 1:20, 5%	x		
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS NO RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: No handicapped accessible parking spaces

LOCATION: Laviolette Field

SITE ACCESS, PATH OF TRAVEL, ENTRANCES

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		x	no paths just open field
Disembarking area at accessible entrance		x	
Surface evenly paved or hard-packed		x	
No ponding water		x	
Path of Travel			
Path does not require the use of stairs		x	
Path is stable, firm, and slip resistant		x	
3 ft wide minimum		x	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		x	
Continuous common surface, no changes in level greater than 1/2 inch		x	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		x	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		x	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		x	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		x	
Level space extending 5 ft from the door, interior and exterior of entrance doors		x	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		x	
At least 18" clear floor area on latch, pull side of door		x	
Door handle no higher than 48" and operable with a closed fist		x	
Vestibule is 4 ft plus the width of the door swinging into the space		x	
Entrance(s) on a level that makes elevators accessible		x	
Door mats less than 1/2" thick are securely fastened		x	
Door mats more than 1/2" thick are recessed		x	
Grates in path of travel have openings of 1/2" maximum		x	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		x	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		x	

NOTES: no grates, signage or usable structures

LOCATION: Laviolette Field

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No stairs, doors, usable structure

LOCATION: Laviolette Field

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: One ADA approved 'Port-o-Potty' with broken door

LOCATION: Laviolette Field

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: Not Applicable, None of the Above

LOCATION: Laviolette Field

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

LOCATION: Laviolette Field

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

LOCATION: Laviolette Field

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTES: Not Applicable, None of the Above

Facility Inventory

LOCATION: Industrial Park Green Belt

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
		Located adjacent to accessible paths
	Trash Cans	Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Location from accessible parking Shade provided		
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths Handrails
		Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: Industrial Park Green Belt

PARKING			
<i>Total Spaces</i>	<i>5 Spaces</i>	<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%	x		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	N/A
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	N/A
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTES: Gravel Parking lot to Conservation Land

LOCATION: Industrial Park Green Belt

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: Small parking area with foot path trails

LOCATION: Industrial Park Green Belt

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No built structures

LOCATION: Industrial Park Green Belt

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: No built structures

LOCATION: Industrial Park Green Belt

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: No built structures

LOCATION: Industrial Park Green Belt

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Industrial Park Green Belt

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Industrial Park Green Belt

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: No built structures

Facility Inventory

LOCATION: HRYNIEWICZ PARK

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface: No Located adjacent to accessible paths
Trash Cans	Located adjacent to accessible paths : Yes	
Picnic Shelters	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material: Asphalt
		Dimensions: 5ft wide
		Rails No
		Signage (for visually impaired): No
Swimming Facilities	Pools No	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches No	Location from accessible path into water
		Handrails
		Location from accessible parking Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all: No
	Access Routes	Located adjacent to accessible paths: Yes
		Enough space between equipment for wheelchair: No
Game Areas: *ballfield *basketball None *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions Spectator Seating
Boat Docks No	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities No	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION: HRYNIEWICZ PARK

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 Space		
26-50	2 Spaces		
51-75	3 Spaces		
76-100	4 Spaces		
101-150	5 Spaces		
151-200	6 Spaces		
201-300	7 Spaces		
301-400	8 Spaces		
401-500	9 Spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance	X		
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		X	N/A
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		X	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		X	
Sign with international symbol of accessibility at each space or pair of spaces		X	
Sign minimum 5ft, maximum 8ft to top of sign	X		
Surface evenly paved or hard-packed (no cracks)	X		
Surface slope less than 1:20, 5%	X		
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present	X		
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	X		
RAMPS NONE			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		X	
Minimum width 4 ft between hand rails		X	
Handrails on both sides if ramp is longer than 6 ft		X	
Handrails at 34" and 19" from ramp surface		X	
Handrails extend 12" beyond top and bottom		X	
Handgrip oval or round		X	
Handgrip smooth surface		X	
Handgrip diameter between 1 1/4" and 2"		X	
Clearance of 1 1/2" between wall and wall rail		X	
Non-slip surface		X	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		X	

LOCATION: HRYNIEWICZ PARK

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	X		
Disembarking area at accessible entrance	X		
Surface evenly paved or hard-packed	X		
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant	X		
3 ft wide minimum	X		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	X		
Continuous common surface, no changes in level greater than 1/2 inch	X		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: No enclosed buildings. One ADA unaccessible Gazebo

LOCATION: HRYNIEWICZ PARK

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers	X		
Nosings not projecting		X	
Treads no less than 11" wide	X		
Handrails on both sides		X	
Handrails 34"-38" above tread	X		
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		X	
Handgrip oval or round		X	
Handgrip has a smooth surface		X	
Handgrip diameter between 1 1/4" and 1 1/2"		X	
1 1/2" clearance between wall and handrail		X	
Doors NONE			
Minimum 32" clear opening		X	
At least 18" clear floor space on pull side of door		X	
Closing speed minimum 3 seconds to within 3" of the latch		X	
Maximum pressure 5 pounds interior doors		X	
Threshold maximum 1/2" high, beveled on both sides		X	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		X	
Hardware minimum 36", maximum 48" above the floor		X	
Clear, level floor space extends out 5 ft from both sides of the door		X	
Door adjacent to revolving door is accessible and unlocked		X	
Doors opening into hazardous area have hardware that is knurled or roughened		X	

NOTES: Not Applicable, None of the Above

LOCATION: HRYNIEWICZ PARK

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: Not Applicable, No Restrooms

LOCATION: HRYNIEWICZ PARK

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: Not Applicable, None of the Above

LOCATION: HRYNIEWICZ PARK

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

LOCATION: HRYNIEWICZ PARK

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

LOCATION: HRYNIEWICZ PARK

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTES: Not Applicable, None of the Above

Facility Inventory

LOCATION: ENDELSON (BONDSDVILLE) PLAYGROUND

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

NOTE: None of the above, just a couple of benches. Just a dilapidated old and un-used tot lot. Not ADA accessible

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 Space		
26-50	2 Spaces		
51-75	3 Spaces		
76-100	4 Spaces		
101-150	5 Spaces		
151-200	6 Spaces		
201-300	7 Spaces		
301-400	8 Spaces		
401-500	9 Spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTE: No Ramps

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: NO BUILT STRUCTURE

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		X	
Nosings not projecting		X	
Treads no less than 11" wide		X	
Handrails on both sides		X	
Handrails 34"-38" above tread		X	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		X	
Handgrip oval or round		X	
Handgrip has a smooth surface		X	
Handgrip diameter between 1 1/4" and 1 1/2"		X	
1 1/2" clearance between wall and handrail		X	
Doors			
Minimum 32" clear opening		X	
At least 18" clear floor space on pull side of door		X	
Closing speed minimum 3 seconds to within 3" of the latch		X	
Maximum pressure 5 pounds interior doors		X	
Threshold maximum 1/2" high, beveled on both sides		X	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		X	
Hardware minimum 36", maximum 48" above the floor		X	
Clear, level floor space extends out 5 ft from both sides of the door		X	
Door adjacent to revolving door is accessible and unlocked		X	
Doors opening into hazardous area have hardware that is knurled or roughened		X	

NOTES: NO STAIRS OR DOORS

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: NO RESTROOMS OR FACILITIES

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: NONE OF THE ABOVE

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

LOCATION: ENDELSON (BONDSVILLE) PLAYGROUND

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground		X	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

NOTE: NONE OF THE ABOVE

Facility Inventory

LOCATION: EAGER PARK/LEGION FIELD

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

NOTES: Swimming not ADA accessible, Tot Lot not ADA accessible, Tennis Court not ADA accessible

LOCATION: EAGER PARK/LEGION FIELD

PARKING 2 spaces, used by residence of local apartments			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

LOCATION: EAGER PARK/LEGION FIELD

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	x		
Disembarking area at accessible entrance	x		
Surface evenly paved or hard-packed	x		
No ponding water	x		
Path of Travel			
Path does not require the use of stairs	x		
Path is stable, firm, and slip resistant	x		
3 ft wide minimum	x		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	x		
Continuous common surface, no changes in level greater than 1/2 inch	x		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		x	none
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		x	none
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		x	no curbs, except continuous berm around tennis court
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		x	
Level space extending 5 ft from the door, interior and exterior of entrance doors		x	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		x	
At least 18" clear floor area on latch, pull side of door		x	
Door handle no higher than 48" and operable with a closed fist		x	
Vestibule is 4 ft plus the width of the door swinging into the space		x	
Entrance(s) on a level that makes elevators accessible		x	
Door mats less than 1/2" thick are securely fastened		x	
Door mats more than 1/2" thick are recessed		x	
Grates in path of travel have openings of 1/2" maximum		x	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		x	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		x	

NOTES: No public or built structures

LOCATION: EAGER PARK/LEGION FIELD

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: NO STAIRS OR DOORS

LOCATION: EAGER PARK/LEGION FIELD

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: NO PUBLIC RESTROOMS

LOCATION: EAGER PARK/LEGION FIELD

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: Not Applicable

LOCATION: EAGER PARK/LEGION FIELD

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	Wading pool
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface	x		

LOCATION: EAGER PARK/LEGION FIELD

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: EAGER PARK/LEGION FIELD

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

Note: No Shower or picnicking

Facility Inventory

LOCATION: EAGER PARK/LEGION FIELD

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

NOTES: Swimming not ADA accessible, Tot Lot not ADA accessible, Tennis Court not ADA accessible

LOCATION: EAGER PARK/LEGION FIELD

PARKING 2 spaces, used by residence of local apartments			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

LOCATION: EAGER PARK/LEGION FIELD

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	x		
Disembarking area at accessible entrance	x		
Surface evenly paved or hard-packed	x		
No ponding water	x		
Path of Travel			
Path does not require the use of stairs	x		
Path is stable, firm, and slip resistant	x		
3 ft wide minimum	x		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	x		
Continuous common surface, no changes in level greater than 1/2 inch	x		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		x	none
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		x	none
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		x	no curbs, except continuous berm around tennis court
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		x	
Level space extending 5 ft from the door, interior and exterior of entrance doors		x	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		x	
At least 18" clear floor area on latch, pull side of door		x	
Door handle no higher than 48" and operable with a closed fist		x	
Vestibule is 4 ft plus the width of the door swinging into the space		x	
Entrance(s) on a level that makes elevators accessible		x	
Door mats less than 1/2" thick are securely fastened		x	
Door mats more than 1/2" thick are recessed		x	
Grates in path of travel have openings of 1/2" maximum		x	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		x	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		x	

NOTES: No public or built structures

LOCATION: EAGER PARK/LEGION FIELD

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: NO STAIRS OR DOORS

LOCATION: EAGER PARK/LEGION FIELD

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: NO PUBLIC RESTROOMS

LOCATION: EAGER PARK/LEGION FIELD

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: Not Applicable

LOCATION: EAGER PARK/LEGION FIELD

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	Wading pool
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface	x		

LOCATION: EAGER PARK/LEGION FIELD

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: EAGER PARK/LEGION FIELD

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

Note: No Shower or picnicking

Facility Inventory

LOCATION: Walter 'Bebbee' Chase Memorial Park

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
		Back and Arm Rests	
		Adequate Number	
	Grills	Height of Cooking Surface	
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located adjacent to accessible paths	
		Located near accessible water fountains, trash can, restroom, parking, etc	
Trails		Surface material	
		Dimensions	
		Rails	
		Signage (for visually impaired)	
Swimming Facilities	Pools	Entrance	
		Location from accessible parking	
		Safety features i.e. warning for visually impaired	
	Beaches	Beaches	Location from accessible path into water
			Handrails
			Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all	
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair	
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths Berm cuts onto courts	
	Equipment	Height	
		Dimensions	
		Spectator Seating	
Boat Docks	Access Routes	Located adjacent to accessible paths	
		Handrails	
Fishing Facilities	Access Routes	Located adjacent to accessible paths	
		Handrails	
	Equipment	Arm Rests	
		Bait Shelves	
		Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim	
		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired		
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

Note: None of this applies, there are no facilities, it is a soccer field with a fence

LOCATION: Walter 'Bebbe' Chase Memorial Park

PARKING			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	no handicap spaces, gravel lot
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS no ramps			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

Notes: NO ADA parking, signage, or curbs. One trash can.

LOCATION: Walter 'Bebbee' Chase Memorial Park

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: No paths. Entire site has a 1% -2% slope

LOCATION: Walter 'Beebe' Chase Memorial Park

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		x	
Nosings not projecting		x	
Treads no less than 11" wide		x	
Handrails on both sides		x	
Handrails 34"-38" above tread		x	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		x	
Handgrip oval or round		x	
Handgrip has a smooth surface		x	
Handgrip diameter between 1 1/4" and 1 1/2"		x	
1 1/2" clearance between wall and handrail		x	
Doors			
Minimum 32" clear opening		x	
At least 18" clear floor space on pull side of door		x	
Closing speed minimum 3 seconds to within 3" of the latch		x	
Maximum pressure 5 pounds interior doors		x	
Threshold maximum 1/2" high, beveled on both sides		x	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		x	
Hardware minimum 36", maximum 48" above the floor		x	
Clear, level floor space extends out 5 ft from both sides of the door		x	
Door adjacent to revolving door is accessible and unlocked		x	
Doors opening into hazardous area have hardware that is knurled or roughened		x	

NOTES: No structures

LOCATION: Walter 'Bebbe' Chase Memorial Park

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTE: One non ADA compliant port-o-potty

LOCATION: Walter 'Beebe' Chase Memorial Park

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: Not applicable, none of the above

LOCATION: Walter 'Bebbee' Chase Memorial Park

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: Walter 'Bebbee' Chase Memorial Park

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: Walter 'Bebbee' Chase Memorial Park

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTES: Not applicable, none of the above

Facility Inventory

LOCATION: Burleigh Park

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		NO
		Access to Open Spaces
		NO
	Grills N/A	Back and Arm Rests
		NO
	Trash Cans N/A	Adequate Number
Height of Cooking Surface		
Picnic Shelters	Located adjacent to accessible paths	
	NO	
Trails	unimproved foot paths	Located near accessible water fountains, trash can, restroom, parking, etc
		Surface material
		Dimensions
		Rails
Swimming Facilities	Pools n/A	Signage (for visually impaired)
		Entrance
		Location from accessible parking
	Beaches N/A	Safety features i.e. warning for visually impaired
		Location from accessible path into water
		Handrails
		Location from accessible parking
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Shade provided
	Access Routes	Same experience provided to all
		Located adjacent to accessible paths
Game Areas: *ballfield *basketball *tennis	Access Routes	Enough space between equipment for wheelchair
		Located adjacent to accessible paths
	Equipment	Berm cuts onto courts
		Y
		Height
Boat Docks	Access Routes	Dimensions
		Spectator Seating
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

NOTE: Base Ball Fields, tennis courts/basketball with no nets, horseshoe courts. None is ADA accessible

LOCATION: Burleigh Park

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 Space		
26-50	2 Spaces		
51-75	3 Spaces		
76-100	4 Spaces		
101-150	5 Spaces		
151-200	6 Spaces		
201-300	7 Spaces		
301-400	8 Spaces		
401-500	9 Spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		X	none
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		X	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		X	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		X	
Sign with international symbol of accessibility at each space or pair of spaces		X	
Sign minimum 5ft, maximum 8ft to top of sign		X	
Surface evenly paved or hard-packed (no cracks)		X	loose gravel, pieces of broken pavement
Surface slope less than 1:20, 5%		X	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		X	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		X	
RAMPS	N/A		
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		X	
Minimum width 4 ft between hand rails		X	
Handrails on both sides if ramp is longer than 6 ft		X	
Handrails at 34" and 19" from ramp surface		X	
Handrails extend 12" beyond top and bottom		X	
Handgrip oval or round		X	
Handgrip smooth surface		X	
Handgrip diameter between 1 1/4" and 2"		X	
Clearance of 1 1/2" between wall and wall rail		X	
Non-slip surface		X	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		X	

LOCATION: Burleigh Park

SITE ACCESS, PATH OF TRAVEL, ENTRANCES

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		X	
Disembarking area at accessible entrance		X	
Surface evenly paved or hard-packed		X	
No ponding water		X	
Path of Travel			
Path does not require the use of stairs		X	
Path is stable, firm, and slip resistant		X	
3 ft wide minimum		X	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		X	
Continuous common surface, no changes in level greater than 1/2 inch		X	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		X	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		X	
Curb on the pathway must have curb cuts at drives, parking, and drop-offs		X	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		X	
Level space extending 5 ft from the door, interior and exterior of entrance doors		X	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		X	
At least 18" clear floor area on latch, pull side of door		X	
Door handle no higher than 48" and operable with a closed fist		X	
Vestibule is 4 ft plus the width of the door swinging into the space		X	
Entrance(s) on a level that makes elevators accessible		X	
Door mats less than 1/2" thick are securely fastened		X	
Door mats more than 1/2" thick are recessed		X	
Grates in path of travel have openings of 1/2" maximum		X	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		X	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		X	

NOTES: No specific ADA accessibility, no curbs, no nets in ball courts, picnic area not accessible, no delineated pathways other than trails in the woods

LOCATION: Burleigh Park

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs Ptwood and earth uneven riser width and height			
No open risers		X	
Nosings not projecting		X	
Treads no less than 11" wide		X	
Handrails on both sides		X	
Handrails 34"-38" above tread		X	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		X	
Handgrip oval or round		X	
Handgrip has a smooth surface		X	
Handgrip diameter between 1 1/4" and 1 1/2"		X	
1 1/2" clearance between wall and handrail		X	
Doors N/A			
Minimum 32" clear opening		X	
At least 18" clear floor space on pull side of door		X	
Closing speed minimum 3 seconds to within 3" of the latch		X	
Maximum pressure 5 pounds interior doors		X	
Threshold maximum 1/2" high, beveled on both sides		X	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		X	
Hardware minimum 36", maximum 48" above the floor		X	
Clear, level floor space extends out 5 ft from both sides of the door		X	
Door adjacent to revolving door is accessible and unlocked		X	
Doors opening into hazardous area have hardware that is knurled or roughened		X	

NOTES: openings to dugouts not ADA accessible, horseshoe courts not ADA accessible, trail network is not ADA accessible, ADA compliant 'Port-o-Potty' is 6" off the ground and therefor not ADA accessible

LOCATION: Burleigh Park

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		X	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		X	
Mounted without pedestal or legs, height 34" to top of rim		X	
Extends at least 22" from the wall		X	
Open knee space a minimum 19" deep, 30" width, and 27" high		X	
Cover exposed pipes with insulation		X	
Faucets operable with closed fist (lever or spring activated handle)		X	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		X	
Stall door is 36" wide		X	
Stall door swings out		X	
Stall door is self closing		X	
Stall door has a pull latch		X	
Lock on stall door is operable with a closed fist and 32" above the floor		X	
Coat hook is 54" high		X	
Toilet			
18" from center to nearest side wall		X	
42" minimum clear space from center to farthest wall or fixture		X	
Top of seat 17"-19" above the floor		X	
Grab Bars			
On back and side wall closest to toilet		X	
1 1/4" diameter		X	
1 1/2" clearance to wall		X	
Located 30" above and parallel to the floor		X	
Acid-etched or roughened surface		X	
42" long		X	
Fixtures			
Toilet paper dispenser is 24" above floor		X	
One mirror set a maximum 38" to bottom (if tilted, 42")		X	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		X	

NOTES: No permanent restrooms

LOCATION: Burleigh Park

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		X	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		X	
Corridor width minimum is 3 ft		X	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		X	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		X	
Hand operated push button or level controls		X	
Spouts located near front with stream of water as parallel to front as possible		X	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		X	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		X	
Telephones			
Highest operating part a maximum 54" above the floor		X	
Access within 12" of phone, 30" high by 30" wide		X	
Adjustable volume control on headset so identified		X	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		X	
Electrical outlets centered no lower than 18" above the floor		X	
Warning signals must be visual as well as audible		X	
Signs			
Mounting height must be 60" to centerline of the sign		X	
Within 18" of door jamb or recessed		X	
Letters and numbers at least 1 1/4" high		X	
Letters and numbers raised .03"		X	
Letters and numbers contrast with the background color		X	

NOTES: None of the Above

LOCATION: Burleigh Park

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		X	
Lifting device		X	
Transfer area 18" above the path of travel and a minimum of 18" wide		X	
Unobstructed path of travel not less than 48" wide around pool		X	
Non-slip surface		X	

N/A

LOCATION

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		X	
Floors are pitched to drain the stall at the corner farthest from the entrance		X	
Floors are non-slip surface		X	
Controls operate by a single lever with a pressure balance mixing valve		X	
Controls are located on the center wall adjacent to the hinged seat		X	
Shower heads attached to a flexible metal hose		X	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		X	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		X	
Soap trays without handhold features unless they can support 250 pounds		X	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		X	
Grab bars are placed horizontally at 36" above the floor line		X	

N/A

LOCATION

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		X	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		X	
Top of table no higher than 32" above ground	X		
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		X	tables on lawn unstable tables in pavilion on cement
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		X	

Facility Inventory

LOCATION: BONDSVILLE GRAMMER PARK

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate Number
	Grills	Height of Cooking Surface
Picnic Shelters	Trash Cans	Located adjacent to accessible paths
		Located adjacent to accessible paths
	Picnic Shelters	Located adjacent to accessible paths
		Located near accessible water fountains, trash can, restroom, parking, etc
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

NOTE: None of the above, just a couple of benches. PASSIVE use park.

LOCATION: BONDSVILLE GRAMMER PARK

PARKING on street with curb			
<i>Total Spaces</i>		<i>Required Accessible Spaces</i>	
Up to 25		1 Space	
26-50		2 Spaces	
51-75		3 Spaces	
76-100		4 Spaces	
101-150		5 Spaces	
151-200		6 Spaces	
201-300		7 Spaces	
301-400		8 Spaces	
401-500		9 Spaces	
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Accessible space located closest to accessible entrance		x	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft		x	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle		x	
Van Space- minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		x	
Sign with international symbol of accessibility at each space or pair of spaces		x	
Sign minimum 5ft, maximum 8ft to top of sign		x	
Surface evenly paved or hard-packed (no cracks)		x	
Surface slope less than 1:20, 5%		x	
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		x	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		x	
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Slope Maximum 1:12		x	
Minimum width 4 ft between hand rails		x	
Handrails on both sides if ramp is longer than 6 ft		x	
Handrails at 34" and 19" from ramp surface		x	
Handrails extend 12" beyond top and bottom		x	
Handgrip oval or round		x	
Handgrip smooth surface		x	
Handgrip diameter between 1 1/4" and 2"		x	
Clearance of 1 1/2" between wall and wall rail		x	
Non-slip surface		x	
Level platforms (4 ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction		x	

NOTE: No Ramps

LOCATION: BONDSVILLE GRAMMER PARK

SITE ACCESS, PATH OF TRAVEL, ENTRANCES

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		x	ADA Accesable from sidewalk
Disembarking area at accessible entrance		x	
Surface evenly paved or hard-packed	x		
No ponding water	x		
Path of Travel			
Path does not require the use of stairs	x		
Path is stable, firm, and slip resistant	x		
3 ft wide minimum	x		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	x		
Continuous common surface, no changes in level greater than 1/2 inch	x		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	x		
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	x		
Curb on the pathway must have curb cuts at drives, parking, and drop-offs	x		
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		x	
Level space extending 5 ft from the door, interior and exterior of entrance doors		x	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		x	
At least 18" clear floor area on latch, pull side of door		x	
Door handle no higher than 48" and operable with a closed fist		x	
Vestibule is 4 ft plus the width of the door swinging into the space		x	
Entrance(s) on a level that makes elevators accessible		x	
Door mats less than 1/2" thick are securely fastened		x	
Door mats more than 1/2" thick are recessed		x	
Grates in path of travel have openings of 1/2" maximum		x	
Signs at non-accessible entrance(s) indicate direction to accessible entrance		x	
Emergency egress- alarms with flashing lights and audible signals, sufficiently lighted		x	

NOTES: NO BUILT STRUCTURE

LOCATION: BONDSVILLE GRAMMER PARK

STAIRS and DOORS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stairs			
No open risers		X	
Nosings not projecting		X	
Treads no less than 11" wide		X	
Handrails on both sides		X	
Handrails 34"-38" above tread		X	
Handrail extends a minimum of 1 ft beyond top and bottom rise (if no safety hazard and space permits)		X	
Handgrip oval or round		X	
Handgrip has a smooth surface		X	
Handgrip diameter between 1 1/4" and 1 1/2"		X	
1 1/2" clearance between wall and handrail		X	
Doors			
Minimum 32" clear opening		X	
At least 18" clear floor space on pull side of door		X	
Closing speed minimum 3 seconds to within 3" of the latch		X	
Maximum pressure 5 pounds interior doors		X	
Threshold maximum 1/2" high, beveled on both sides		X	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		X	
Hardware minimum 36", maximum 48" above the floor		X	
Clear, level floor space extends out 5 ft from both sides of the door		X	
Door adjacent to revolving door is accessible and unlocked		X	
Doors opening into hazardous area have hardware that is knurled or roughened		X	

NOTES: NO STAIRS OR DOORS

LOCATION: BONDSVILLE GRAMMER PARK

RESTROOMS- also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
5 ft turning space measured 12" from the floor		x	
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach		x	
Mounted without pedestal or legs, height 34" to top of rim		x	
Extends at least 22" from the wall		x	
Open knee space a minimum 19" deep, 30" width, and 27" high		x	
Cover exposed pipes with insulation		x	
Faucets operable with closed fist (lever or spring activated handle)		x	
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep		x	
Stall door is 36" wide		x	
Stall door swings out		x	
Stall door is self closing		x	
Stall door has a pull latch		x	
Lock on stall door is operable with a closed fist and 32" above the floor		x	
Coat hook is 54" high		x	
Toilet			
18" from center to nearest side wall		x	
42" minimum clear space from center to farthest wall or fixture		x	
Top of seat 17"-19" above the floor		x	
Grab Bars			
On back and side wall closest to toilet		x	
1 1/4" diameter		x	
1 1/2" clearance to wall		x	
Located 30" above and parallel to the floor		x	
Acid-etched or roughened surface		x	
42" long		x	
Fixtures			
Toilet paper dispenser is 24" above floor		x	
One mirror set a maximum 38" to bottom (if tilted, 42")		x	
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor		x	

NOTES: NO RESTROOMS OR FACILITIES

LOCATION: BONDSVILLE GRAMMER PARK

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Floors			
Non-slip surface		x	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		x	
Corridor width minimum is 3 ft		x	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		x	
Drinking Fountains			
Spouts no higher than 36" from floor to outlet		x	
Hand operated push button or level controls		x	
Spouts located near front with stream of water as parallel to front as possible		x	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		x	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		x	
Telephones			
Highest operating part a maximum 54" above the floor		x	
Access within 12" of phone, 30" high by 30" wide		x	
Adjustable volume control on headset so identified		x	
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Switches, Controls, and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		x	
Electrical outlets centered no lower than 18" above the floor		x	
Warning signals must be visual as well as audible		x	
Signs			
Mounting height must be 60" to centerline of the sign		x	
Within 18" of door jamb or recessed		x	
Letters and numbers at least 1 1/4" high		x	
Letters and numbers raised .03"		x	
Letters and numbers contrast with the background color		x	

NOTES: NONE OF THE ABOVE

LOCATION: BONDSVILLE GRAMMER PARK

SWIMMING POOLS- accessibility can be via ramp, lifting device, or transfer area			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		x	
Lifting device		x	
Transfer area 18" above the path of travel and a minimum of 18" wide		x	
Unobstructed path of travel not less than 48" wide around pool		x	
Non-slip surface		x	

LOCATION: BONDSVILLE GRAMMER PARK

SHOWER ROOMS- Showers must accommodate both wheel-in and transfer use			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
Stalls 36" by 60" minimum, with a 36" door opening		x	
Floors are pitched to drain the stall at the corner farthest from the entrance		x	
Floors are non-slip surface		x	
Controls operate by a single lever with a pressure balance mixing valve		x	
Controls are located on the center wall adjacent to the hinged seat		x	
Shower heads attached to a flexible metal hose		x	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		x	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		x	
Soap trays without handhold features unless they can support 250 pounds		x	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		x	
Grab bars are placed horizontally at 36" above the floor line		x	

LOCATION: BONDSVILLE GRAMMER PARK

PICNICKING			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/ Transition Notes</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access		x	
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide, and 24" deep.		x	
Top of table no higher than 32" above ground		x	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions		x	
Accessible tables, grills, and fire rings must have clear ground space of at least 36" around the perimeter		x	

NOTE: NONE OF THE ABOVE